


II – 7. Framework scaffolding (upper section)



1. Is there a passageway between the scaffolding and the building?
2. Is the scaffolding clear of materials?
3. Have terminal blocks been installed?
4. Has vertical netting been installed?
5. Is the load less than 400 kg per span?
6. Is the working platform at least 40 cm wide?
Are gaps in the working platform no more than 3 cm wide?
7. Are you using a safety belt on the scaffolding?
8. Is the space between the scaffolding and the building no more than 30 cm?
9. Has horizontal netting been installed where gaps exceed 30 cm?