


VI Preventing Electric Shock Accidents

VI – 1 . Temporary lighting



1. Are all electric bulbs and sockets free of damage?
2. Is there a bulb cover?
3. Are all cables free of damage?
4. Are flexible cables used?
5. Are the flexible cables undamaged?
6. Are the flexible cables used as rope?
7. Are any portions of the flexible cables overheated?
8. Are the plugs undamaged?