


VI – 2. Working near overhead power lines



1. Have the positions of power lines been checked?
2. Have safety provisions been discussed with the electric company?
3. Have voltage, position, and distance been checked?
Have danger signs been posted?
4. Is the area roped off to prevent electrical shock?
5. Have power lines been fitted with protective covers?
6. Has a lookout been stationed?
7. Has a safe distance been ensured between the crane and power lines?